

General Environmental Incident Summary

Incident: 4011 **Date/Time Notice:** 1/28/2016 1351 **DEM Incident No:**

Responsible Party: ONEOK Rockies Midstream

Date Incident: 1/28/2016 **Time Incident:** 1100 **Duration:**

County: Williams **Twp:** 155 **Rng:** 103 **Sec:** 21 **Qtr:**

Lat: 48.22760 **Long:** -103.94100 **Method:** Interpolation from map

Location Description: Stateline Gas Plant
15071 56th At NW
Williston ND 58801

Submitted By: Kim Rudningen

Affiliation: Env Spec. ONEOK

Address: 2700 Lincoln Ave SE

City: Sidney

State: MT

Zip:

Received By:

Contact Person: Kim Rudningen
2700 Lincoln Ave SE
Sidney, MT 59270

Distance Nearest Occupied Building:

Release Contained: Yes

Type of Incident: Pump Leak

Description of Released Contaminant: Natural Gas Condensates

Volume Spilled: 1.00 gallons

Ag Related: No

EPA Extremely Hazardous Substance: Unknown

Reported to NRC: Unknown

Cause of Incident:

PSV for the pump was found to be leaking fluid out of the weephole for the vent to atmosphere. This is located by the condensate tank truck load out.

Risk Evaluation:

There are no immediate risks associated with this release

of Fatalities:

of Injuries:

Affected Medium: 03 - soil

Potential Environmental Impacts:

This release is fully contained to the facility site with no impact to surface or ground water. Soil will be remediated.

Action Taken or Planned:

Operator blocked in the PSV to stop leak and parts to repair have been ordered. Impacted soil and gravel will be removed and containerized for disposal.

Wastes Disposal Location: Certified landfill

Agencies Involved:

Updates

Date: 1/29/2016 ***Status:*** Reviewed - No Action Required

Author: Crowdus, Kory

Updated Volume:

Notes:

Due to the small amount released and rapid cleanup, no further followup is required.